

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 09/06/25

It is certified that an inspection team headed by Dr. Anshu Agarwal M.O.I.C.

(Name of Officers with designation) from PHC Naya Gaon Peliya Dehradun PHED

inspected the Doon Yudhishtera Public School, Sheeshambhara, Dehradun

(Name & Address of the school) on 09/06/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. Sample Id 050625/01 dated 05/06/2025

of METesting and Calibration Lab Pvt. Ltd. (PHED Lab) certified that

the Doon Yudhishtera Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 09/06/2026

Signature with Seal:

Name

Designation

Name & Address of the Office / Department PHC Naya Gaon Peliya Dehradun

To THE DOON YUDHISHTERA PUBLIC SCHOOL

DEHRADUN
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

प्रभारी चिकित्सा अधिकारी
प्रा० स्वा० केन्द्र
नया गाँव पेलियो, देहरादून



METESTING AND CALIBRATION LABORATORY PVT. LTD.

Head Office: 103, 1st Floor, Plot No. C-1/2 Naniwala Bagh,
Commercial Complex, Azadpur, Delhi, India - 110033
Mobile: +91 7535000491, +91 9034341490 | Email: metclplddn@gmail.com

Lab.: Harbanswala, Telpur Chowk, Shimla Bypass Road,
Dehradun, Uttarakhand, India - 248171
Mobile: +91 7535000491, +91 7535000492 | Email: metclddn@gmail.com

Doc. No.: METCLPL/FF/48

TEST REPORT

| | |
|--|---|
| Issued To: THE DOON YUDHISHTERA PUBLIC SCHOOL, MUNJAL ESTATE RAMGARH SHEESHAMBARA SHIMLA BY PASS DEHRADUN | ULR No.: TC143902500000504F Sample Id: 050625/01 Date of Receipt: 05/06/2025 Date of performance of Testing: 05 - 07/06/2025 Date of Issue of Report: 07/06/2025 |
| Sample Description: Drinking Water Sample Quantity: 1 Ltr. Sample Condition: Packed in Plastic Bottle. Sample Plan & Sampling Method: N/A. Environment Condition (Temp. & Humidity): 25.0 \pm 5 $^{\circ}$ C & NA Addition to, Deviation or Exclusion from the Method: NA | Test Performed at: Lab Page No.: 1 of 1 |

Requirement as per IS: 10500-2012 RA: 2018 (Drinking Water)

| S.No. | Characteristics | Test -Value | Required (Acceptable Limit) | Permissible Limit in absence of Alternate Source | Method of Test | Conformity |
|-------|---|-------------|-----------------------------|--|------------------------------|------------|
| 1 | Colour, Hazen unit. Max. | 1 | 5 | 15 | IS-3025(P-4)-2021 | Yes |
| 2 | Odour | Agreeable | Agreeable | Agreeable | IS- 3025(P-5)-1983 | Yes |
| 3 | Turbidity, NTU. | 0.2 | 1 Max. | 5 Max. | IS-3025(P-10)-2023 | Yes |
| 4 | pH. Value | 7.25 | 6.5 - 8.5 | No Relaxation | IS-3025(P-11)-2022 | Yes |
| 5 | Total Hardness, (as CaCO ₃), mg/l | 31.37 | 200 Max. | 600 Max. | IS-3025(P-21)-2009 RA: 2019 | Yes |
| 6 | Iron (as Fe), mg/l | 0.21 | 0.3 Max. | No Relaxation | IS-3025(P-53)-2003 RA: 2019 | Yes |
| 7 | Chloride (as Cl), mg/l | 22.5 | 250 Max. | 1000 Max. | IS-3025(P-32)-1988 RA: 2019 | Yes |
| 8 | Fluoride (as F), mg/l | Nil | 1.0 Max. | 1.5 Max. | IS: 3025(P-60)-2008 RA: 2019 | Yes |
| 9 | Total Dissolved Solids, mg/l | 50.0 | 500 Max. | 2000 Max. | IS-3025(P-16)-2023 | Yes |

Remarks: With respect to the above test, sample complies with specification.

Note: 1. The Above Test refers only to the Items tested.

2. Statement of Conformity & Decision Rule (In case of Borderline): N.A.

3. Opinion & Interpretations: N.A.

*****End of Report*****



Mr. Rahul Rohilla (C.M./T.M)

Authorized Signatory


Reviewed By

- The result listed refer only to the tested samples and applicable parameters endorsement of product is neither inferred nor implied.
- Total liability of our Lab. is limited to the invoiced amount.
- Samples will be destroyed after 30 Days from the date of issue of test report.
- This report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any



TO WHOM SO EVER IT MAY CONCERNED

THIS IS TO CERTIFY THAT "THE DOON YUDHISHTERA PUBLIC SCHOOL"
LOCATION AT MUNJAL ESTATE, RAMGARH SHEESHAMBARA, SHIMLA BY-PASS
DEHRADUN. INSPECTION WAS CONDUCTED BY HEALTH OFFICER NAYA GAON
DURING INSPECTION THE SCHOOL'S DRINKING WATER, CLEANING AND
SANITARY CONDITION WERE FOUND SAFE AND SATISFACTORY.

1

16.12.23
प्रभारी चिकित्सा अधिकारी
प्रा० स्वा० केन्द्र
नया गाँव पेलिबो, देहरादून

TO WHOM SO EVER IT MAY CONCERNED

THIS IS TO CERTIFY THAT "THE DOON YUDHISHTERA PUBLIC SCHOOL" LOCATION AT MUNJAL ESTATE, RAMGARH, SHEESHAMBARA, SHIMLA BY-PASS DEHRADUN INSPECTION WAS CONDUCTED BY HEALTH OFFICER NAYA GAON. DURNING INSPECTION THE SCHOOL'S DRINKING WATER, CLEANING AND SANITRY CONDITION WERE FOUND SAFE AND SATISFACTORY.

Heu
18/08/2022 .
प्रभारी चिकित्सा अधिकारी
प्रा० स्वा० केन्द्र
नया गाँव पेलियो, देहरादून

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE

NO. Health Insp/2019DATE: 12-07-2019

It is certified that an Inspection team headed by

DR. D. S. PUNDEERMEDICAL OFFICER

(Name of Officers with designation)

from Ad. Naya Gaon Paliyo


(Name of Department/Office) inspected the

The Deen Yudhishtira Public SchoolRam Jank Sheeshambada

(Name & Address of the School) on

DEHRADUN and found that the DEHRADUN (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of for one year effect
from 20/9-2020

Signature with Seal: Name: DR. D. S. PUNDEERMedical OfficerDesignation Ad. P.H.C. Naya Gaon PaliyoDehradun (U.K.)

To

